

Fuente de Alimentación



L x W x H mm	IP	CLASS	V in	Frecuencia	V out	Corriente de salida	W min	W max	Factor de potencia	Protocolo	Código
99x82x30	20		120-373 85-230	43-63Hz	24	DC AC	-	50	0,95	-	18131
99x97x30	20		120-373 85-230	43-63Hz	24	DC AC	-	75	0,9	-	18125
140x63x32	67		142-431 100-305	43-63Hz	24	DC AC	-	75	0,9	-	18140
129x97x30	20		120-373 85-230	43-63Hz	24	DC AC	-	100	0,9	-	18141
140x63x32	67		142-431 100-305	43-63Hz	24	DC AC	-	100	0,92	-	18124
191x63x37.5	67		127-431 90-305	43-63Hz	24	DC AC	-	120	0,9	DALI	18164
159x97x30	20		120-370 85-264	47-63Hz	24	DC AC	-	150	0,89	-	18132
180x63x35.5	67		142-431 100-305	47-63Hz	24	DC AC	-	150	0,93	-	18133
228x68x38.8	65		120-370 85-264	47-63Hz	24	DC AC	-	150	0,93	1-10V/PMW SIGNAL	18167
195x68x39.5	67		142-431 100-305	47-63Hz	24	DC AC	-	199	0,93	DALI2	18165
244x71x37.5	67		142-431 100-305	47-63Hz	24	DC AC	-	240	0,9	1-10V/PMW SIGNAL	18162
244x71x37.5	67		142-431 100-305	47-63Hz	24	DC AC	-	240	0,9	DALI	18163
215x115x30	20		240-370 90-132	47-63Hz	24	DC AC	-	350	0,83	-	18138
252x90x43.8	67		127-431 90-305	47-63Hz	24	DC AC	-	320	0,9	-	18142

Fuente de Alimentacion para Low Voltage Tracks Din Rail

L x W x H mm	IP	CLASS	V in	Frecuencia	V out	Corriente de salida	W min	W max	Factor de potencia	Protocolo	Código
32x125.2x102	20	B	127-310 90-264	47-63Hz	48	DC AC	-	75	0,88	-	16450
40x125.2x113.5	20	B	127-310 90-264	47-63Hz	48	DC AC	-	120	0,88	-	16451
63x125.2x113.5	20	B	127-310 90-264	47-63Hz	48	DC AC	-	240	0,88	-	16452

Transformador / Transformador 12V



12V AC

L x W x H mm	IP	V in	Frecuencia	V out	Corriente de salida		W min	W max	Protocol
150x20x50	65	127	50-60Hz	12	AC	ELECTRONICO	-	6	19000-L
150x20x50	65	127	50-60Hz	12	AC	ELECTRONICO	-	50	TE-HAL-50
150x20x50	65	127	50-60Hz	12	AC	ELECTRONICO	-	60	19000
149 x 68 x 115	68/1 M	127	50-60Hz	12	AC	MAGNETICO	-	100	11151

Equipos de control



IP20

L x W x H mm	IP	CLASS	V in	DC V out	W max x canal	W max total	Protocol		
153x65x20	20		12V DC 24V DC	12 24	30 60	60 120	1-10V	2	11187